

From

Director General
Fire Service, Haryana Panchkula

To

M/s ADHIYAMAAN EDUCATIONAL AND RESEARCH INSTITUTIONS
khasra no 2//25 6//5 6 15/1 16/1 village budhena sector 86 tehsil faridabad
Memo No. FS/2024/112 dated : 18/01/2024

Subject :

Fire Safety Certificate 15 mtrs. and Above from the fire safety point of view for Group B-
Educational Building at khasra no 2//25 6//5 6 15/1 16/1 village budhena sector 86 tehsil faridabad
of ADHIYAMAAN EDUCATIONAL AND RESEARCH INSTITUTIONS :

Reference your letter no. 030152323001319 dated 20/12/2023 on the subject cited above.

Tower Name	Floor Detail	Height	Ground Coverage
Block 1 (Part FSC)	G+2	11.43 mtr.	916.092 Sq. mtr.
Tower Name	Basement Level	Basement Area	Basement Remarks
Nil	Nil	Nil	Nil

- 1) The owner/occupier shall give a self declaration certificate annually regarding fire safety system installed in his building/premises is working in good condition and there is no addition alteration in the building.
- 2) In case there is any addition/alteration in the building, the Fire Safety Certificate shall cease to exist and the owner shall apply for approval of revised Fire Fighting Scheme
- 3) As per sub-section (1) and the competent authority may randomly check such building/premises.
- 4) The owner/occupier shall keep duly trained Fire Staff in all three shifts
- 5) The Fire Protection System tested during inspection shall be maintained properly & always should be in good working condition.
- 6) If any lapse is found in the fire protection system at the time of inspection or detected during outbreak of fire, action will be taken as per rules against you.
- 7) You are directed to apply for Fire Safety Certificate in future before 2 months of expiry of your Fire Safety Certificate
- 8) The open set back area is not checked at our end as it shall be checked by concerned building authority/department.
- 9) The owner/occupier shall strictly follow the other applicable rules/ regulations/ byclaws laid down regarding fire safety system. If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Section, 30,31 & 7 of Fire & Emergency Services Act 2022.
- 10) You have to perform quarterly Fire Drill in your building as per NBC with intimation to Fire Department and video graphy evidence to be kept as a record which shall be produced at the time of next Renewal. Official Staff should be participated in the drill
- 11) If the Infringements of Byelaws remains un-noticed the Authority reserves the right to amend the Fire Safety Certificate as and when any such Infringements comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 12) Fire safety Certificate granted subject to condition that there is no violation in sanctioned building plan by virtue of which fire fighting scheme was approved
- 13) The owner or occupier of the building shall give a self-declaration certificate annually to the effect that the fire fighting system installed in his building is working in good condition and there is no addition alteration in the building. The Fire Officer may randomly check such building. In case there is any addition/alteration beyond permissible limits under the Haryana Building Code, 2017, the fire safety certificate shall cease to exist and the owner shall apply for approval of revised Fire Fighting Scheme as per the provisions of section 18.

The above Fire Safety Certificate is valid for only **Three** year from the date of issue of this letter Applying renewal of the same well in time shall be the responsibility of owner/occupier.

Remarks:- As per undertaking given by owner the Part FSC issued subject to the condition that the firm installed the remaining fire System within 06 months and the owner is sole responsible for this otherwise FSC can be deemed cancel



Aruna Binoal
Principal
St. Peter's International School
Sector-86, Faridabad

Deputy Director (Technical)-I,



Digitally signed by Deputy Director (Technical)-I,
KALRA Haryana
Date: 2024.01.18 12:39:13 +05:30
Reason: Digital Verification

Exercising the power of Director, Fire Services, Haryana